

**HEALTH**


**6.10 Designated Aerobic Treatment Unit Area**

<i>Responsible Department</i>	Development Services - Health
<i>Resolution Number</i>	C.4998
<i>Resolution Date</i>	April 2024
<i>Next Scheduled Review</i>	April 2026
<i>Related Shire Documents</i>	Local Planning Scheme 6
<i>Related Legislation</i>	Health (Miscellaneous Provisions) Act 1911

**OBJECTIVE**

To minimise pollution from unsewered development concentrated on flood prone land adjacent the Avon River West of the Northam Townsite.

**SCOPE**



This policy applies to the portion of land bordered by Burn, Burlong, Tankard and Jelling Streets, Northam located west of the Northam townsite.

**POLICY**

All applications for approval of onsite effluent disposal for all new development in the area the subject of this policy are required to install a secondary treatment system with nutrient removal that are approved by the WA Department of Health.

A site and soil evaluation may be required to accompany any applications for on-site sewage disposal.